

Name of Work: Providing Electrical Fittings in 401 Nos. Flats of PAC at Plot No. GH-03, Sector- Omicron-I, Greater Noida

NOIDA METRO RAIL CORPORATION

E- Tender No: NMRC/GM/Tech/PAC/Elect/2020/129

Date: 25.09.2020

Pre- Bid Meeting: September 21, 2020 at the Conference Room, Noida Metro Rail Corporation (NMRC) Limited, Ganga Shopping Complex, Sector- 29, Noida- 201301.

SN	Query Raised By	Clause No. of RFP	Clarification Requested	Existing Provision within RFP	Clarification/ Amended by NMRC*
1	M/s Himalaya Generators	GCC CLAUSE 15.4 (ESI & PF)	As per your contract T&C, 3 works of 40% value, 2 works of 60% value & 1 work of 80% value is your Eligibility criteria- It is not possible to done work of such value without minimum labour not 20 numbers at any point of time. This also mentioned in your GCC clause 15.4 as "All the contractor's employee shall have to be covered ESI and ECA as per special conditions of contract.	Employee shall have EPF & ESI Registration.	As per RFP conditions



2	M/s Himalaya Generators		<u>Character certificate issued by DM in the state of UP or SDM in case of Delhi should be incorporated in your Tender conditions as per order issued by UP Government</u>	Not mentioned in RFP, However an undertaking in Form-7 is demanded against clause 4.1(c) - "The Bidder should not have been blacklisted/ banned/ declared ineligible for corrupt and fraudulent practices by the Government of India/ any State Government/ Government Agency and Supreme court and contracts have been terminated/ foreclosed by any company / department due to non- fulfilment of Contractual obligation in last 5 (five) financial years."	-No change in RFP-
3	M/s Himalaya Generators	BOQ (Sr. No. 1.02)	Supply and fixing of recess/ Surface/ Pendent mounting round 6 Watt 8 Watt LED Down Lighter CAT AAA- <u>Please clarify which light is required at site (recess type or surface type or pendent) and is CAT AAA mandatory?</u>	Supply and fixing of recess/ Surface/ Pendent mounting round 6 Watt 8 Watt LED Down Lighter having Powder coated die cast aluminum housing with heat sink, diffuser/ Reflector and driver set complete in all respect CAT- AAA	No change- As per Tender Conditions. To be provided as per site requirement.

Ch

+

Am

4	M/s Himalaya Generators	BOQ (Sr. No. 2.01)	<p>Supply of 1200 mm ceiling fan of 5 star rating suitable operation of 230 V AC. As per latest BEE rating 5 star ceiling fans are coming with BLDC (brushless DC Electric) motor.</p> <p><u>Please clarify either you will go with BLDC motor (5star rating as specified by BEE) or normal ceiling fan with copper wound motor without BEE rating.</u></p>	<p>Supply of 1200mm ceiling fan of 5 star rating suitable for operation of 230V ac.</p>	<p>Amendment on account of revised BEE 5 star rating ceiling fan specifications and costing. It may read as:</p> <p><u>"Supply of 1200 mm ceiling fan with copper wound motor suitable operation of 230 V AC."</u> Of preferable makes as specified in RFP</p>
5	M/s Himalaya Generators	Clause 4.8	<p>The Performance Guarantee should be valid for a period of 06 (six) months beyond the contract period.</p> <p><u>Please clarify will your department release security deposit after six month from the actual date of completion.</u></p>	<p>The Performance Guarantee should be valid for a period of 06 (six) months beyond the contract period.</p>	<p>-No change- As per RFP conditions-</p>

Handwritten signature

Handwritten mark

Handwritten signature


5	M/s Himalaya Generators	4.11.2 Terms of payments	<p>50 % payment of the supply value of equipment will be made on delivery at NMRC site/s.</p> <p><u>As per other department payment terms, 75% is made on supply of material at site, 20% on successful installation rest 5% after handing over of site, please amend your payment terms as 100% payment for supply is required to place order with manufacturer in order to get fast delivery as your completion time is of 2 months.</u></p>	<p>The standard payment terms subject to recoveries, if any, by way of liquidated damages will be as under.</p> <p>a) 50 % payment of the supply value of equipment will be made on delivery at NMRC site/s.</p> <p>b) 45 % payment on Installation, Testing and Commissioning of whole system after submission of completion certificate issued by NMRC engineer in charge or representative.</p> <p>c) 5% amount of final bill will be withheld during warranty period and same will be released after satisfactory performance during warranty period.</p>	-No change- as per RFP conditions
---	-------------------------	--------------------------	---	---	-----------------------------------

Handwritten signature


Handwritten mark

Handwritten signature

	M/s Himalaya Generators	4.11.3 (B)	GST, if claimed, will be reimbursed only if the GST registration number is mentioned in the invoice. In the absence of GST registration number, GST will not be reimbursed. Please clarify will your department reimburse GST or Taxes Is inclusive as mentioned in your BOQ	GST, if claimed, will be reimbursed only if the GST registration number is mentioned in the invoice. In the absence of GST registration number, GST will not be reimbursed	GST will be reimbursed/paid on submission of Tax Invoice as the contract is inclusive of all taxes and duties including GST etc.
S	Additional query raised during pre-bid by all attending firms	BOQ (Sr. No. 1.01)	Clarification sought about fitting is including LED tube light	Supply and fixing of LED Tube Light batten fitting suitable for up to 1 X 22 watt LED tube light on surface complete in all respect. CAT- AAA	Clarification: CAT-AAA is LED tube light with batten fitting. Amendment: Supply and fixing of LED Tube Light with batten fitting suitable for up to 1 X 22 watt LED tube light on surface complete in all respect. CAT- AAA


(V.V.Reddy)
DGM/Civil


(Rajan Prakash)
DGM/ Finance


(Avinash Kumar)
DGM/ RS,Ops & Elect

Place: - Noida.

Note: -The above amendments/clarification shall supersede all the respective provisions in Tender Documents.